
AIR VELOCITY TRANSDUCERS



TSI's Air Velocity Transducers measure velocities using thermal anemometry.

Three distinct sensor types provide flexibility with wide dynamic ranges for accurate measurements. The durable Model 8455 general-purpose probe and the Model 8465 windowless probe deliver high accuracy with a fast response for a variety of applications. The omnidirectional Model 8475 offers accurate measurements at low velocities and is ideal for varying flow

Three dependable sensors available

AIR VELOCITY TRANSDUCER

General Purpose (8455)

• Protected probe tip

- Rugged ceramic sensor
- Wide range of measurement applications
- Fast response time

Windowless (8465)

- Less flow blockage
- Ideal for measuring in confined spaces
- Fast response time

Omnidirectional (8475)

- Omnidirectional probe tip
- Accurate at low velocities from 0.05 to 0.5 m/s (10 to 100 ft/min)
- Ideal for unknown or varying flow direction

Applications

- Comfort and draft studies
- Critical environment installations like clean rooms and hospitals
- Diffuser design analysis
- Monitoring drying processes
- Monitoring air flows in tunnels and subways
- Used as a standard in wind tunnels and calibration facilities
- Environmental monitoring in greenhouses and IAQ applications
- General engineering applications



direction. All versions come with user selectable ranges and output options.



Air Velocity Transducer Models 8455, 8465, 8475

8455 8465 8475

Accuracy⁷: $\pm 2.0\%$ of reading¹ $\pm 2.0\%$ of reading¹ $\pm 3.0\%$ of reading²

±0.5% of full scale of selected range ±0.5% of full scale of selected range ±1.0% of full scale of selected range

Repeatability: $<\pm 1.0\%$ of reading³ $<\pm 1.0\%$ of reading³ N/A **Response Time to Flow:** $0.2 \sec^4$ $0.2 \sec^4$ $5.0 \sec^5$

Common specifications to all models:

Field Selectable Velocity Ranges

Model 8455/8465: 0.125 m/s to 1.0, 1.25, 1.50, 2.0, 2.5, 3.0, 4.0, 5.0, 7.5, 10.0,

12.5, 15.0, 20.0, 25.0, 30.0, 40.0, 50.0 m/s

(25 ft/min to 200, 250, 300, 400, 500, 750, 1000, 1250, 1500, 2000, 2500, 3000, 4000, 5000, 7500, 10000 ft/min)

Model 8475: 0.05 m/s to 0.5, 0.75, 1.00, 1.25, 1.50, 2.0, 2.5 m/s

(10 ft/min to 100, 125, 150, 200, 250, 300, 400, 500 ft/min)

Minimum Resolution: 0.07% of selected full scale

Input Power: 11-30 VDC or 18-28 VAC, 350mA max⁶

Output Impedance: Voltage mode: less than 1 ohm, 20 mA max source current
Output Resistance: Current mode: 500 ohms maximum load resistance

Output Signal

(field selectable): 0-5V, 0-10V, 2-10V, 0-20mA, 4-20mA

Output Time Constant

(field selectable): 0.05 to 10 seconds.

Probe Length: 7.5 cm, 15 cm, 22.5 cm or 30 cm (3 in., 6 in., 9 in. or 12 in.)

Temperature Range: Compensation Range: 0 to 60°C (32 to 140°F)

Electronics and Sensor Operation: 0 to 93°C (32 to 200°F)

Storage: 0 to 93°C (32 to 200°F)



Accessories:

Model 8495 Display, Monitor and Power Supply

- Provides unregulated 12 VDC power (500 mA) with TSI supplied AC adaptor
- Adjustable full scale reading and signal input
- Digital display indicates velocity
- •User selectable audible and visual alarms

Model 8911 Power Supply

• Provides regulated 12 VDC power (500 mA) from 115 VAC source

Directional sensitivity of the Model 8475 is +5%/-20% of reading +0/-0.05 m/s (+0/-10 ft/min) over 270° solid angle regardless of flow direction.

All specifications subject to change without notice.




TSI Incorporated Environmental Measurements and Controls Division

500 Cardigan Road Shoreview, MN 55126 USA Telephone: 800 777 8356

800 777 8356 **Europe:** 651 490 2711 **TSI AB:**

Fax: 651 490 2874 Telephone: 46 18 527000
E-mail: emco@tsi.com TSI GmbH
Website: www.tsi.com Telephone: 49 241 523030

P/N 2980139 Copyright © 1999 by TSI Incorporated Printed in U.S.A.



¹ From 18 to 28°C (64.4 to 82.4°F), outside this range and within temperature compensation range add 0.2% per °C (0.4 per °F).

 $^{^2}$ From 20 to 26°C (68 to 78.8°F), outside this range and within temperature compensation range add 0.5% per °C (0.9 per °F).

³ Standard deviation, based on one minute average from 0.5 to 5.0 m/s (100 to 1000 ft/min).

⁴ For 63% of final value, tested at 7.5 m/s (1500 ft/min).

⁵ For 63% of final value, tested at 2.5 m/s (500 ft/min).

⁶ Input voltage must be maintained within specifications at the transducer.

⁷ Calibration occurs with sensor oriented horizontally in a horizontal flow. Uncertainty increases in downward vertical flow at velocities less than 50 ft/min (0.25 m/s).